



OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.No. 08/DFO/SRFS/Bng/FSR/2023

OFFICE OF THE DISTRICT FIRE OFFICER  
Karnataka State Fire & Emergency Services  
Sarjapura Road Fire Station  
Bengaluru-560 035.

Date: 06/02/2023

"Annexure-2"

To,  
The Secretary,  
SJR EDUCATION SOCIETY(R)  
SJR Public School, C.A. site No.3 (P),  
HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block,  
Bengaluru-560 043.

Sir,

**Sub :** Issue of "Fire Safety Compliance report" with respect to fire prevention, fire fighting and evacuation measures maintained at "SJR Public School, C.A. site No.3 (P), HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560 043".

**Ref :** 01) This office FSR No. 08/DFO/SRFS/Bng/FSR/2023 Date: 06 -02-2023.  
02) Your request letter dated:-04-02-2023.  
03) C.NO: 01/FSO/SRFS/BNG-2023. Dt:-06-02-2023

<<<<>>>


With reference to the above cited subject, as per ref a conditional Fire Safety Recommendation was issued to the premises of "SJR Public School, C.A. site No.3 (P), HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560 043". with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of "M/s.SJR PUBLIC SCHOOL" had requested for the fire safety compliance report from our department. In this regard the Fire Station officer, Sarjapur road Fire Station, Bengaluru was inspected on 04 -02-2023 and submitted the report to issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to "SJR Public School, C.A. site No.3 (P), HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560 043".

Subject to proper maintenance of fire fighting installations in the good working conditions, one generator of suitable capacity to supply alternative power for staircase lighting, corridor lighting etc., in the event of failure of electricity supply in the building and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This report is valid up to only one year from the date of issue and is renewable without fail".



  
**PRINCIPAL**  
SJR PUBLIC SCHOOL,  
HBR LAYOUT  
BENGALURU-560 043.

  
**SECRETARY**  
Sri Jagadguru Renukacharya  
Education Society,  
Bangalore - 9.

Yours faithfully,  
  
**DISTRICT FIRE OFFICER**  
Sarjapura Road Fire Station  
Bengaluru-560 035.



OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 08/DFO/SRFS/BNG-2023.

OFFICE OF THE DISTRICT FIRE OFFICER  
Karnataka State Fire & Emergency Services  
Sarjapura Road Fire Station  
Bengaluru-560 035.

Date: 06/02/2023

To,

To,

The Secretary,

SJR EDUCATION SOCIETY(R)

SJR Public School, C.A. site No.3 (P),

HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block,

Bengaluru-560043.

Sir,

**Sub :** Issue of "Fire safety recommendation" with respect of fire prevention, fire fighting and evacuation measures required at "M/S .SJR Public School, C.A. site No.3 (P),HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560043."

**Ref :** 1. Your request letter dated: 04-02-2023.

2. C.NO: 01/FSO/SRFS/BNG-2023. Dt:-06-02-2023.

><<<\*@\*<<<<

With reference to the subject cited above, the premises of "M/S SJR Public School, C.A. site No.3 (P),HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560 043" Was inspected Fire Station Officer Sarjapur road on 04-02-2023 for suggesting fire prevention, fire fighting & evacuation measures to be complied in the above premises and has submitted the details as under.

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	Honorable Secretary, SJR Education Society ® SJR Public School, C.A. site No.3 (P), HBR Layout 1 <sup>st</sup> stage, 3 <sup>rd</sup> block, Bengaluru-560043.
02	Name and Address of the premises.	:	SJR Public School, C.A. site No.3 (P), HBR Layout 1 <sup>st</sup> stage, 3 <sup>rd</sup> block, Bengaluru-560043.
03	Name and address of the Building owner	:	SRI JAGADGURU RENUKACHARYA EDUCATION SOCIETY. No.9,Race course Road, Near Ananda Rao circle, Bengaluru-560009.
04	Number of buildings	:	One building

  
**SECRETARY**  
Sri Jagadguru Renukacharya  
Education Society,  
Bengaluru - 9.

  
**PRINCIPAL**  
SJR PUBLIC SCHOOL  
HBR LAYOUT  
BENGALURU 560043

05	Number of floors	:	Lower Ground floor + Upper ground floor + 3 upper floor.
06	<b>Floor-wise details of occupancy:-</b>		
	Lower ground floor	:	Class rooms-12, Group room-02, Fees counter-01, wash rooms-02, Accounts room-01, Administrative room-01, Table Tennis room-01, Activity room-01, Electrical Room-01, Server room-01, Teachers cabin room-06, Special activity room-06.
	Upper Ground floor	:	Class room-08, Vice principal room-01, Committee Room-01, Principal room-01, Group room-01, Computer lab-01, Staff room-01, wash room-02, Teachers cabin-06.
	1 <sup>st</sup> floor	:	Class rooms-07, Activity room-01, Auditorium-01, Library room-01, Group room-01, Teachers cabin-06, wash rooms-02.
	2 <sup>nd</sup> floor	:	Class room-07, Store room-02, Lab-01, Teachers cabin-06, wash rooms-02.
	3 <sup>rd</sup> floor	:	Class rooms-14, Lab-01, Store room-01, Group room-01, Wash rooms-02.
07	Height of the building	:	14.80 mtrs
08	Site area	:	6200.37 Sqmtrs
09.	<b>Built-up area of each floor:-</b>		
	Lower ground floor	:	2140.56 Sq. mtrs.
	Upper Ground floor	:	2026.90 Sq. mtrs.
	1 <sup>st</sup> floor	:	1829.01 Sq. mtrs.
	2 <sup>nd</sup> floor	:	1837.35 Sq. mtrs.
	3 <sup>rd</sup> floor	:	1790.75 Sq. mtrs.
10.	<b>Total built-up area</b>	:	9624.97 Sq. mtrs
11.	<b>Surrounding properties:-</b>		
	East(side)	:	5th cross road
	West(side)	:	6 <sup>th</sup> cross road
	North(rear)	:	8 <sup>th</sup> main road
	South(Front)	:	7 <sup>th</sup> main road
12.	<b>Set-back area available around the building :-</b>		
	East(side)	:	06.00 mtrs
	West(side)	:	4.00 mtrs
	North(rear)	:	4.00 mtrs
	South(Front)	:	3.00 mtrs

*Pulmath*  
**SECRETARY**  
 Sri Jagadguru Renukacharya  
 Education Societey,  
 Bangalore - 9.



*AS*  
**PRINCIPAL**  
**SJR PUBLIC SCHOOL,**  
 HBR LAYOUT  
 BENGALURU-560 043.



B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																					
01.	Accessibility to the premises	The Premises is accessible from 12.00mtrs wide on East, west, South & Northern side & hard enough to carry the weight of 45.000.kgs.	Complied																					
02.	No. of entrances	02 entrance & exit from north of 5 mtrs From south 01 entrance of 3.00 mtrs and 01 entrance from west of 3.00 mtrs has been provided.	Complied																					
03.	Width of entry / exit	Entrance / Exit- 5.30 mtrs.	Complied																					
04.	Diesel generators.	Not Provided.	As Proposed to provide One suitable Capacity of generator should be provided																					
05.	No. of staircases available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>03 Stair case</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>01.00 mtrs each</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 cms each</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 cms each</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>10 Nos each</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>00.90 mtrs each</td> </tr> <tr> <td>Head room clearance</td> <td>:</td> <td>2.20 mtrs each</td> </tr> </table>	Nos. of staircases	:	03 Stair case	Width of staircases	:	01.00 mtrs each	Width of treads	:	30 cms each	Height of risers	:	15 cms each	Nos. of riser per flight	:	10 Nos each	Height of handrails	:	00.90 mtrs each	Head room clearance	:	2.20 mtrs each	Complied.
Nos. of staircases	:	03 Stair case																						
Width of staircases	:	01.00 mtrs each																						
Width of treads	:	30 cms each																						
Height of risers	:	15 cms each																						
Nos. of riser per flight	:	10 Nos each																						
Height of handrails	:	00.90 mtrs each																						
Head room clearance	:	2.20 mtrs each																						
06.	Fire extinguisher	06 Nos. of ABC fire extinguishers, each Of 6 kg capacity, 02 Nos. of CO2 fire extinguishers, each Of 4.5 kg capacity have been provided in The Building.	Complied.																					
07.	First aid Hose reel hose.	02 No's of Hose Reel Hose has been provided near the Staircases Hose Reel Hose of 19 mm size of	Complied.																					

*Abhinav*  
**SECRETARY**  
 Sri Jagadguru Renukacharya  
 Education Society,  
 Bangalore

*AS*  
**PRINCIPAL**  
**SJR PUBLIC SCHOOL**  
 HBR LAYOUT  
 BENGALURU-560 043.

		adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5 mm size. Have been Provided.	
08.	Terrace tank over respective tower terrace.	20,000 liters capacity of terrace tank has been provided.	Complied.
09.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> .	A booster pump has been installed at the terrace level capable of delivering 450 liters of water per minute.	Complied.
10.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied.
11.	Fire order	Fire order board has been displayed near each staircase of ground floor with <b>emergency Telephone Numbers of Sarjapura Road Fire Station i.e. 25746166 &amp; 101</b> and telephone numbers of nearest Ambulance Service & Management.	complied
12	No Smoking board.	No Smoking board shall be displayed.	Complied
13	Fire Siren	A Fire Siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14	Nominate one fire Nodal Officer	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied
15	Fire fighting training	Not trained	The 40% of staff or employees Should Be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29.

*P. Ananth*  
**SECRETARY**  
 Sri Jagadguru Renukacharya  
 Education Societey,  
 Bangalore - 9.



*AS*  
**PRINCIPAL**  
**SJR PUBLIC SCHOOL**  
 HBR LAYOUT  
 BENGALURU-560 043.

General Fire precaution measures :-

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustibile waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should be not stored in the building.
- E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14<sup>th</sup> of every year by conducting fire safety drills with co-ordinate with Fire Service Department.
- H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing **Fire safety recommendation** & **Fire Compliance Certificate** to SJR Public School, C.A. site No.3 (P), HBR Layout 1<sup>st</sup> stage, 3<sup>rd</sup> block, Bengaluru-560043. Subject to Condition and compliance of the above recommendations as shown in column-15 of part-B within 3 months and compliance from the undersigned.

"This Fire safety Recommendation is valid for only one year from the date of issue and it is renewable".

4. All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

  
**PRINCIPAL**  
**SJR PUBLIC SCHOOL,**  
HBR LAYOUT  
BENGALURU-560 043.

  
**SECRETARY**  
**Sri Jagadguru Renukacharya**  
Education Societey,  
Bangalore - 8

Yours faithfully



**DISTRICT FIRE OFFICER**  
Sarjapura Road Fire Station  
Bengaluru-560 035.